


BLOCK WATER TESTING LABORATORY, ABOHARHanuman Garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

TEST REPORT						
Name & Address of Customer : AKAL ACADEMY KHUIAN SARWAR VPO GIDDERANWALI BLOCK KHUIAN SARWAR			Customer Reference No.		No : letter no.AAKS/62/26 Dated : 27/03/2026	
			Sample Submitted by		Ranjeet Singh	
			Date of Sample Receipt		27/03/2026	
			Analysis Starting Date		27/03/2026	
			Analysis completion Date		28/03/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		Abohar/2526/00309		Date of Issue :		28/03/2026
Registration no.:		Abohar/REG2526/02221		Condition of Sample :		Sealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Akal Academy VPO GIDDERANWALI BLOCK KHUIAN SARWAR (RO Water) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Khuiian Sarwar		District :		Fazilka
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.32@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	170	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	96	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	136	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	38.4	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	96	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%


Headmistress
Akal Academy
Khuian Sarwar.(Fzk.)

Reviewed and Approved By



Ashish Kumar
Sr. Chemist
Authorized Signatory
For,Block Water Testing Laboratory
Abohar


Manager
AKAL ACADEMY
Khuian Sarwar

----- End of the Test Report -----

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road in Water works Near Bye pass, Abohar
bwtlab@gmail.com

To,

AKAL ACADEMY KHUIAN SARWAR
VPO GIDDERANWALI BLOCK KHUIAN SARWAR

No.: Abohar/2526/00309 Dated : 28/03/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. letter no.AAKS/62/26 Dated: 27/03/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 27/03/2026. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report


Headmistress
Akal Academy
Khuian Sarwar.(Fzk.)



Manager
AKAL ACADEMY
Khuian Sarwar
Authorized Signatory
For, Block Water Testing Laboratory
Abohar

Performa Regarding Safe Drinking Water and Sanitary Condition Certificate

No. 432

Date- 14/05/2026

It is Certified that an inspection Team from Water Supply and Sanitation Sub Division Khuian Sarwar inspected the Akal Academy, Khuian Sarwar, VPO Giddranwali, Tehsil-Abohar Distt-Fazilka And Drinking Water Sample test report issued by District Water Testing Laboratory vide Report No. Abohar/2526/00309 Date 28.03.2026 Found that the Akal Academy Khuian Sarwar, VPO Giddranwali, Tehsil-Abohar Distt-Fazilka has safe drinking water facilities for the students and members of staff of the institution and is maintaining the good sanitation condition in the school building.

The above is valid till 31.03.2027



Sub-Divisional Engineer
W/S & Sanitation Sub Division
Khuian Sarwar

To

Akal Academy Khuian Sarwar, VPO Giddranwali,

Tehsil-Abohar Distt-Fazilka



Headmistress
Akal Academy
Khuian Sarwar.(Fzk.)



Manager
AKAL ACADEMY
Khuian Sarwar