


**Performa Regarding Safe Drinking Water and Sanitary Condition
Certificate**

No. 536

Date- 26.05.2025

It is Certified that an inspection Team from Water Supply and Sanitation Sub Division Khuian Sarwar inspected the **Akal Academy Khuian Sarwar, VPO Giddranwali, Tehsil-Abohar Distt-Fazilka** and Drinking Water Sample test report issued by District Water Testing Laboratory vide Report No. Abohar/2526/00028 Date 05.05.2025 Found that the Akal Academy Khuian Sarwar, VPO Giddranwali, Tehsil-Abohar Distt-Fazilka has safe drinking water facilities for the students and members of staff of the institution and is maintaining the good sanitation condition in the school building.

The above is valid till 31.03.2026




Sub Divisional Engineer
Water Supply and Sanitation Sub Division
Khuian Sarwar

To

Akal Academy Khuian Sarwar, VPO Giddranwali,
Tehsil-Abohar Distt-Fazilka



**Manager
Akal Academy**



**Headmistress
Akal Academy
Khuian Sarwar.(Fzk.)**

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

To,

HEAD MISTRESS ,AKAL ACADEMY,KHUIAN SARWAR
V.P.O.GIDDRAALI ,KHUIAN SARWAR

No.: Abohar/2425/00022 Dated : 09/08/2024

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. SRF NO. 22 Dated: 24/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 24/07/2024. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar



Manager
Akal Academy



Headmistress
Akal Academy
Khuian Sarwar.(Fzk.)

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

TEST REPORT

Name & Address of Customer : HEAD MISTRESS ,AKAL ACADEMY,KHUIAN SARWAR V.P.O.GIDDRAALI ,KHUIAN SARWAR		Customer Reference No.	No : SRF NO. 22 Dated : 24/07/2024
		Sample Submitted by	RANJEET SINGH
		Date of Sample Receipt	24/07/2024
		Analysis Starting Date	26/07/2024
		Analysis completion Date	27/07/2024
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	Abohar/2425/00022	Date of Issue :	09/08/2024
Registration no.:	Abohar/REG2425/00024	Condition of Sample :	Unsealed
Collection Point:	Private Hand Pump	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Gidderanwali	Habitation :	Gidderanwali
Block:	Khuian Sarwar	District :	Fazilka
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.40@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	650	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	3	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	240	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	252	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	82	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	20	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	80	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju Sarwar

Mrs. Manju
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

Headmistress
Headmistress
Akai Academy
Khuian Sarwar.(Fzk.)

Manager
Manager
Akai Academy

End of the Test Report